

Date.....

Permit No. 84-92

TOWN OF ACTON

APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

1. Permittee: H.S. Builders Corp. Address: 1001 Shrewsbury St., Woburn, Mass. 01801
- 1A. Telephone #:
2. Location of Proposed Construction: Willow St. #165
3. Purpose of Construction: Rep. Street 6 ft
4. Length of Cut: 26'
5. Width of Cut: 5'
6. Width of Existing Pavement: 26'
7. Type of Existing Roadway Surface: Asphalt Type of Curb: Concrete
8. Type of Existing Sidewalk Surface: Asphalt Type of Shoulder: Gravel
9. Date of Street Opening: From 8/29/84 To 9/1/84
10. For Work Involving Excavations: Dig Safe Number 814 211 47

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated August 3, 1982. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Special Instructions:

Signature of Applicant: [Signature]

1. Backfill must be compacted in 6" lifts by mechanical means. Backfill must be suitable gravel material free of large stones.
2. A temporary hot top patch must be in place by the close of work the day the cut is made. The applicant must maintain the temporary patch in good condition until the permanent patch is in place.
3. The permanent hot top patch to Town specifications must be in place by December 1, 1984.

INSP 11-8-84 D.A. & D.H.
1) H2O SERVICE IN E HAS HOT TOP PATCH
HOLD BOND THRU WINTER FOR SETTLEMENT
INSP 1-17-86 - PATCH IN LITTLE SETTLEMENT JOINT NEED SEALING!

Permit Issued: Date OCT. 22, 1984 By: D. Allet


Application Denied: Date By:

Work Inspected and Approved: Date SEPT. 15, 1986 By: Dennis R. Rany

(over)

D.R. & T.W.
INSP 8-14-86 JOINTS NOT
SEALED - PATCH HAS SETTLED


TOWN OF ACTON TYPICAL DRIVEWAY 8 TRENCH DETAIL FEB. 1969 NO SCALE





NOTE: 1. FINAL PATCH DEPTH
3. OIL TREATED ROADS
4. BIT. CONC. ROADS
2. SEE SPECIFICATIONS FOR
FURTHER REQUIREMENTS

SKETCH

SECTION A-A







Date: October 30, 1984

FROM: Engineering Department

TO: Town Treasurer

SUBJECT: Bond-Permit to Construct Within a Public Way

Please hold the enclosed Bond in the form of:

Certified Check # _____ Bank _____

Pass Book # 100-38680 Bank Assabet Inst. for Savings

Other (Specify) _____

in the amount of \$500.00 from (Applicant) L & S Builders, Corp.

as security for "Permit to Construct Within a Public Way" # 84-92

located at Willow Street; for authority

see Section IV-A, Specifications for Regulating Construction Within

Public Ways. This bond is to be held until released in writing by

this department.

Signed: David J. Allen
Asst. Town Engineer

TOWN OF ACTON

ENGINEERING DEPARTMENT

DATE: 1-21-86

TO: L & S Builders Corp.

SUBJECT: Notice of Inspection - Permit to Construct Within a Public Way # 84-92

LOCATION: 165 Willow St.

The following work remains to be done:

The joints of the water cut patch needs sealing to prevent water from
undermining and freezing.

Please contact us when the work is completed.

Signed

David Albert
Town Engineer



TOWN OF ACTON, MA 01720
DEPARTMENT OF PUBLIC WORKS

ENGINEERING

NOTICE OF INSPECTION

TO: L&S BUILDERS CORP.

SUBJECT: PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY # 84-92

LOCATION: #165 WILLOW STREET

DATE: AUGUST 15, 1986

THE FOLLOWING WORK REMAINS TO BE DONE:

Our records indicate that you were instructed to repair the patch over the water connection on Willow Street on January 1, 1986. A recent inspection revealed that this work is still incomplete. Therefore, please be advised that the Town will be taking the bond currently being held and will apply it towards repair of the street. The bond amount being taken is \$500.00

If you have any questions please feel free to contact me at 264-9628.

SIGNED: *David L. Allen*

TITLE: ENGINEERING
ADMINISTRATOR

Date: SEPTEMBER 17, 1986

FROM: Engineering Department

TO: Town Treasurer

SUBJECT: Bond - Permit to Construct Within a Public Way

Please release the bond in the form of:

Certified Check # _____ Bank _____

Pass Book # 100-38680 Bank ASSABET INST. FOR SAVINGS

Other (Specify) _____

in the amount of \$500.00 to L+S BUILDERS

which is being held as security for "Permit to Construct Within
a Public Way" # 84-92, Located at Willow STREET,
for authority see Section II - A specification for regulation of
construction within public ways.

Work proposed under this permit has been satisfactorily completed.

Signed: Daniel Albert

